

| | | |
|----------------|----------------------------|----------------------------------|
| ELEMENT | COMPLIES (or NA) | DOES NOT COMPLY |
|----------------|----------------------------|----------------------------------|

ACCESSIBLE TRANSIENT LODGING (Sleeping / Dormitory Rooms)

| | | | | | | | | | | | | |
|--|---|------|-------|-------|--------|---------|---------|---------|---------|---------|-------------|-------------------|
| APPLICABLE | Except as specified below, Accessible Transient Lodging shall comply with this section. In addition, public and common use areas of accessible transient lodging shall comply with all other applicable accessibility sections of this checklist. | | | | | | | | | | | |
| FHA | Note that ALL sleeping units shall comply with the Fair Housing Act. Accessible Units , in addition, shall require special mobility features. | | | | | | | | | | | |
| ACCESSIBLE UNITS | Total number of sleeping units provided: [] | | | | | | | | | | | |
| Accessible sleeping units required | Total Units | 1-25 | 26-50 | 51-75 | 76-100 | 101-150 | 151-200 | 201-300 | 301-400 | 401-500 | 501-1000 | 1001 & over |
| | Accessible Units | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 2% of total | 20 + 1/100 > 1000 |
| (Plus) | | | | | | | | | | | | |
| Accessible Units w/ Roll-in Showers | | | 1 | 1 | 2 | 2 | 3 | 4 | 4 | 4 | 1% of total | |
| Number of accessible units required: [] | | | | | | | | | | | | |
| Number of accessible units provided: [] <input type="checkbox"/> <input type="checkbox"/> | | | | | | | | | | | | |
| Number of accessible units with roll-in showers required: [] | | | | | | | | | | | | |
| Number of accessible units with roll-in showers provided: [] <input type="checkbox"/> <input type="checkbox"/> | | | | | | | | | | | | |

| | | | | | | | | | | | | |
|---|------------------|------|-------|-------|--------|---------|---------|---------|---------|---------|-------------|-------------------|
| Accessible sleeping units for persons with hearing impairments | Total Units | 1-25 | 26-50 | 51-75 | 76-100 | 101-150 | 151-200 | 201-300 | 301-400 | 401-500 | 501-1000 | 1001 & over |
| | Accessible Units | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 2% of total | 20 + 1/100 > 1000 |
| Number of accessible units required: [] | | | | | | | | | | | | |
| Number of accessible units provided: [] <input type="checkbox"/> <input type="checkbox"/> | | | | | | | | | | | | |

| | | | |
|---|--|--------------------------|--------------------------|
| ACCESSIBLE UNITS | Accessible Units (shall be dispersed among the various types and sizes provided) | <input type="checkbox"/> | <input type="checkbox"/> |
| | Sleeping area (36" min. on both sides of the bed) | <input type="checkbox"/> | <input type="checkbox"/> |
| | Turning area (Clear floor space with 60" diameter unobstructed circle required) | <input type="checkbox"/> | <input type="checkbox"/> |
| | When provided, all areas of accessible units shall be accessible: (living, dining, one sleeping area, one full bathroom, patios/terraces/balconies, parking/garages) | | |
| When provided, complete the applicable [DOORS; TOILET ROOMS; BATHTUBS AND SHOWERS; KITCHENS] sections of checklist) | | | |

| | | | |
|-------------------|--|--------------------------|--------------------------|
| STORAGE | Built in closets, shelves, and drawers shall be accessible. Controls shall be accessible. (see clear floor space, reach range, hardware below) | <input type="checkbox"/> | <input type="checkbox"/> |
| Clear floor space | <p>(a) forward (b) parallel</p> | | |
| | Reach range (15 – 48" forward reach; 9 – 54" side reach, max. 10" deep) | <input type="checkbox"/> | <input type="checkbox"/> |
| Reach range | | | |

| ELEMENT | COMPLIES (or NA) | DOES NOT COMPLY | |
|--|--|---|---|
| Reach range | <p>Reach range over obstruction (< 20" deep obstruction w/ knee space, 48" AFF max. forward; 20-25" deep obstruction w/ knee space, 44" AFF max. forward reach; < 10" deep obstruction, 34" high obstruction, 54" max. side; 10-24" deep, 34" high obstruction, 46" AFF max. side reach)</p> | <input type="checkbox"/> <input type="checkbox"/> | |
| | | | |
| <p>Hardware (operable with one hand without tight pinching, twisting, or turning of wrist; max. 5# of force)</p> | | | <input type="checkbox"/> <input type="checkbox"/> |

| | |
|--|--|
| DOORS | Complete DOORS section |
| TOILET FACILITIES | Complete TOILET ROOMS section |
| BATHING FACILITIES / (ROLL-IN SHOWERS) | Complete BATHTUBS AND SHOWERS section |
| KITCHENS | Complete KITCHENS section |
| ALARMS | Complete ALARMS section |