

ELEMENT		COMPLIES (or NA)	DOES NOT COMPLY										
<b>BUSINESS AND MERCANTILE</b>													
APPLICABLE	All areas used for business transactions with the public shall comply with this section. In addition, public and common use areas of business and mercantile shall comply with all other applicable accessibility sections of this checklist.												
DOOR	If provided, complete <b>DOOR</b> section												
SALES and SERVICE COUNTERS	Counters with cash registers (min of one counter with: min. 36" long section, max. 34" AFF ( <i>IAC requirement</i> ))	<input type="checkbox"/>	<input type="checkbox"/>										
INFORMATION COUNTERS	Counters without cash registers (portion of main counter: min. 36" long section, max. 34" AFF; or auxiliary counter at 34" AFF ( <i>IAC requirement</i> ); or equivalent facilitation provided)	<input type="checkbox"/>	<input type="checkbox"/>										
CHECK-OUT COUNTERS	Total number of check-out aisles provided: [      ]												
Check-out Aisles required	<table border="1"> <tr> <td>Total Aisles</td> <td>1-4</td> <td>5-8</td> <td>8-15</td> <td>over 15</td> </tr> <tr> <td>Accessible # Req'd.</td> <td>1</td> <td>2</td> <td>3</td> <td>3 + 20% of additional aisles</td> </tr> </table>			Total Aisles	1-4	5-8	8-15	over 15	Accessible # Req'd.	1	2	3	3 + 20% of additional aisles
Total Aisles	1-4	5-8	8-15	over 15									
Accessible # Req'd.	1	2	3	3 + 20% of additional aisles									
	Number of accessible check-out aisles required: [      ]												
	Number of accessible check-out aisles provided: [      ] <input type="checkbox"/> <input type="checkbox"/>												
	Check-out aisles (36" min. aisle width; adjoining counter max. 38" AFF; 40" max. AFF counter lip) <input type="checkbox"/> <input type="checkbox"/>												
	Signage (accessible check-out aisle identified; International Symbol of Accessibility) <input type="checkbox"/> <input type="checkbox"/>												
SHELVES AND DISPLAY	Self-service shelves and display (located on an accessible route; reach ranges requirements do not apply)	<input type="checkbox"/>	<input type="checkbox"/>										
	Security Bollards (shall not prevent access/egress for people in wheelchairs)	<input type="checkbox"/>	<input type="checkbox"/>										
INTERIOR ACCESSIBLE ROUTE	Complete <b>INTERIOR ACCESSIBLE ROUTE</b> section												