

ELEMENT		COMPLIES (or NA)	DOES NOT COMPLY
<b>DOORS</b>			
APPLICABLE	<p>The following shall comply:</p> <ul style="list-style-type: none"> <li>At each accessible entry to a building or facility, a minimum of one door shall comply with this section.</li> <li>Within a building or facility, a minimum of one door at each accessible space shall comply with this section.</li> <li>Each door that is part of an accessible route shall comply with this section.</li> <li>Each door that is part of an accessible means of egress or connecting to an area of rescue assistance shall comply with this section.</li> </ul>		
GATES	Gates, including ticket gates shall comply with the applicable portions of this section.		
REMOVING DOORS AND TURNSTILES	Revolving doors and turnstiles shall not be the only means of passage along an accessible route or at a entry.	<input type="checkbox"/>	<input type="checkbox"/>
DOORS	Automatic door opener provided [YES] or [NO]	<input type="checkbox"/>	<input type="checkbox"/>
Maneuvering clearance at swing doors	Maneuvering clearance at door provided (see figs. below) (if automatic door <u>not</u> provided)	<input type="checkbox"/>	<input type="checkbox"/>
	<p>(a) front approach, pull side</p> <p>(b) front approach, push side</p> <p>(c) front approach, push side</p> <p>(d) hinge approach, pull side</p> <p>(e) hinge approach, pull side</p> <p>(f) hinge approach, push side</p> <p>(g) hinge approach, push side</p> <p>(h) latch approach, pull side</p> <p>(i) latch approach, pull side</p> <p>(j) latch approach, push side</p> <p>(k) latch approach, push side</p>		
Maneuvering clearance at sliding doors	<p>(a) front approach</p> <p>(b) pocket or hinge approach</p> <p>(c) stop or latch approach</p>		
	Opening force (max. 8.5# force exterior (IAC), 5# force interior, 5# sliding or folding (if automatic door <u>not</u> provided))	<input type="checkbox"/>	<input type="checkbox"/>
	Door hardware (lever or bar pull, 34 - 48" AFF; no round knob or thumb push)	<input type="checkbox"/>	<input type="checkbox"/>

ELEMENT		COMPLIES (or NA)	DOES NOT COMPLY
	Vision lights (bottom of glass min. 43" AFF)	<input type="checkbox"/>	<input type="checkbox"/>
	Swinging door / gate surface (10" AFF and total width shall be smooth)	<input type="checkbox"/>	<input type="checkbox"/>
	Door clear width (32" min. for one active door)	<input type="checkbox"/>	<input type="checkbox"/>
Clear opening			
	Door closer (if provided, 3 sec. min. closure time from 70° open to a point 3" from the latch)	<input type="checkbox"/>	<input type="checkbox"/>
	Door vestibule (48" min. plus the width of the door swinging into the space)	<input type="checkbox"/>	<input type="checkbox"/>
Vestibule			
	Threshold (1/2" max. height with beveled slope of 1:2, no abrupt change > 1/4")	<input type="checkbox"/>	<input type="checkbox"/>
Threshold			