

ELEMENT	COMPLIES (or NA)	DOES NOT COMPLY
<b>ACCESSIBLE ROUTE – INTERIOR</b> (public route within the building, see ADAAG for scoping requirements)		
WHERE REQUIRED	<p>Shall connect accessible building or facility entrances with all accessible spaces and elements within the building or facility.</p> <p>Shall connect at least one accessible entrance of each accessible dwelling unit with those exterior and interior spaces and facilities serving the accessible dwelling unit.</p> <p>In multi-story buildings not required to have an elevator, floors located above and below the accessible ground floor shall comply with all other applicable accessibility sections of this checklist.</p>	
APPLICABLE	In addition, public and common use areas or elements provided along the accessible route shall comply with all other applicable accessibility sections of this checklist.	

ROUTE	Route width (36" min., except at doors, 32")	<input type="checkbox"/>	<input type="checkbox"/>
Route width	Route width at turns (36" min. for 90° turn, 42" min. with 48" at the end if additional turn required within 48")	<input type="checkbox"/>	<input type="checkbox"/>
Route width			
	Route passing space (intersecting walks, or 5' x 5' spaces req'd. at max. 200' intervals)	<input type="checkbox"/>	<input type="checkbox"/>
	Route slope (1:20 max. running slope; 1:50 max. cross slope)	<input type="checkbox"/>	<input type="checkbox"/>
	Route surface (firm, stable, slip-resistant; no abrupt changes > 1/4")	<input type="checkbox"/>	<input type="checkbox"/>
	Gratings (if provided, 1/2" max. opening width, perpendicular to path of travel)	<input type="checkbox"/>	<input type="checkbox"/>
	Carpet (if provided, 1/2" max. pile thickness, securely attached to floor)	<input type="checkbox"/>	<input type="checkbox"/>
Protruding Objects		<input type="checkbox"/>	<input type="checkbox"/>
	Protruding objects (if leading edge 27"-80" AFF, max. 4" projection to path of travel)	<input type="checkbox"/>	<input type="checkbox"/>
	Protruding objects on poles (if leading edge 27"-80" AFF, max. 12" projection to path of travel)	<input type="checkbox"/>	<input type="checkbox"/>
	Headroom (6'-8" min.)	<input type="checkbox"/>	<input type="checkbox"/>
Protruding Objects			

ELEMENT	COMPLIES (or NA)	DOES NOT COMPLY
DOORS	If provided along interior accessible route, complete <b>DOOR</b> section	
RAMP	If provided along interior accessible route, complete <b>RAMP</b> section	
ELEVATOR	If provided along interior accessible route, complete <b>ELEVATORS</b> section	
LIFT	If provided along interior accessible route, complete <b>PLATFORM LIFT</b> section	
STAIRS	If provided, complete <b>STAIR</b> section if floors are not connected by ramp, elevator or lift	
MEANS OF EGRESS	(coordinate with local building / life safety requirements)	
AREAS OF RESCUE ASSISTANCE	(coordinate with local building / life safety requirements)	