



ELEMENT	COMPLIES (or NA)	DOES NOT COMPLY	
<b>LIBRARIES</b>			
APPLICABLE	All areas of libraries used by the public shall comply with this section. Included are reading rooms, study areas, stacks, reference rooms, reserve areas and special areas for collections. In addition, public and common use areas of libraries shall comply with all other applicable accessibility sections of this checklist.		
DOOR	If provided, complete <b>DOOR</b> section		
CHECK-OUT AISLES / SERVICE COUNTERS	Check-out area (located on an accessible route; min of one counter at each location type with: min. 36" long section, max. 34" AFF ( <i>IAC requirement</i> ))	<input type="checkbox"/>	<input type="checkbox"/>
READING AND STUDY AREAS	Reading areas and study carrels – minimum 5% of each type shall be accessible and be distributed around the facility.	<input type="checkbox"/>	<input type="checkbox"/>
	Clearance between tables and carrels (36" min.)	<input type="checkbox"/>	<input type="checkbox"/>
	Route width at turns (36" min. for 90° turn, 42" min. with 48" at the end if additional turn required within 48")	<input type="checkbox"/>	<input type="checkbox"/>
SEATING and TABLES	Fixed tables or work counters (min. 5% shall be accessible, distributed proportionally throughout; accessible route provided)		
Clear floor space	Clear floor space (30" wide x 48" deep w/ max. 19" of the 48" depth extended below surface)	<input type="checkbox"/>	<input type="checkbox"/>
Table knee & toe clearance	Knee clearance (min. 27" high, 30" wide, 19" deep)	<input type="checkbox"/>	<input type="checkbox"/>
CARD CATALOGS, MAGAZINE DISPLAY & REFERENCE MATERIALS	Table/Counter surface height (28" – 34" AFF)	<input type="checkbox"/>	<input type="checkbox"/>
	Aisle width (36" min. aisle width, 42" preferred)	<input type="checkbox"/>	<input type="checkbox"/>
	Reach range (48" forward and/or side reach)	<input type="checkbox"/>	<input type="checkbox"/>

ELEMENT	COMPLIES (or NA)	DOES NOT COMPLY
---------	---------------------	--------------------



STACKS	Aisle width (36" min. aisle width, 42" preferred) (not that shelf height is unrestricted)	<input type="checkbox"/> <input type="checkbox"/>
--------	---	---



INTERIOR ACCESSIBLE ROUTE	Complete <b>INTERIOR ACCESSIBLE ROUTE</b> section
---------------------------	---