

ELEMENT		COMPLIES (or NA)	DOES NOT COMPLY
RAMP			
WHERE REQUIRED	Wherever the slope of an accessible route exceeds 1:20 (5%). The slope of the ramp should be the least possible and comply with the requirements below.		
RAMP	Clear width (36" min.)	<input type="checkbox"/>	<input type="checkbox"/>
	Ramp slope (1:12 max. running slope; 1:50 max. cross slope)	<input type="checkbox"/>	<input type="checkbox"/>
	Ramp slope alternate (1:10 max. up to 6" high; 1:8 max. up to 3" high)	<input type="checkbox"/>	<input type="checkbox"/>
	Ramp surface (firm, stable, slip-resistant; no abrupt changes > 1/4")	<input type="checkbox"/>	<input type="checkbox"/>
	Ramp rise (max. 30" rise for any one ramp segment)	<input type="checkbox"/>	<input type="checkbox"/>
	Doorways (when located adjacent to ramp, shall have required level maneuvering area at door)	<input type="checkbox"/>	<input type="checkbox"/>
	Landings (min. width = to ramp width; 60" min. length; 60" x 60" min. if change in direction)	<input type="checkbox"/>	<input type="checkbox"/>
Landings	<p>(a) (b)</p>		
HANDRAILS	Handrails (required if ramp height > 6" or horizontal projection exceeds 72" (unless the ramp is a curb ramp); required on both sides of ramp)		
Diameter	Handrail height (34"-38" AFF, w/ 12" extensions beyond top and bottom parallel to ground)	<input type="checkbox"/>	<input type="checkbox"/>
	Handrail (1 1/4" – 2" diameter or equivalent gripping surface w/ 1-1/2" space between handrail and wall)	<input type="checkbox"/>	<input type="checkbox"/>
	<p>(a) circular (b) non-circular (c) non-circular</p>	<input type="checkbox"/>	<input type="checkbox"/>
Dimensions	Handrail (shall be uninterrupted, ends rounded or returned smoothly to floor, wall or post and not rotate in their fittings)	<input type="checkbox"/>	<input type="checkbox"/>
	Edge protection provided (walls, railings, surface extension, or min. 2" high curbs at drop-offs)	<input type="checkbox"/>	<input type="checkbox"/>
	Outdoor ramp (ramp and approach designed so water will not accumulate)	<input type="checkbox"/>	<input type="checkbox"/>
Dimensions	<p>(a) extended surface (b) curb or barrier</p>		