

ELEMENT		COMPLIES (or NA)	DOES NOT COMPLY
RESTAURANTS AND CAFETERIAS			
APPLICABLE	All areas of restaurants and cafeterias used by the public shall comply with this section. In addition, public and common use areas of restaurants and cafeterias shall comply with all other applicable accessibility sections of this checklist.		
DOOR	If provided, complete DOOR section		
SALES and SERVICE COUNTERS	Counters with cash registers (min of one counter with: min. 36" long section, max. 34" AFF (<i>IAC requirement</i>))	<input type="checkbox"/>	<input type="checkbox"/>
SEATING and TABLES	Fixed tables or counters where food is served (min. 5% shall be accessible, distributed proportionally throughout; accessible route provided)		
Clear floor space	Clear floor space (30" wide x 48" deep w/ max. 19" of the 48" depth extended below surface)	<input type="checkbox"/>	<input type="checkbox"/>
Table knee & toe clearance	Knee clearance (min. 27" high, 30" wide, 19" deep)	<input type="checkbox"/>	<input type="checkbox"/>
Counter height	Table/Counter surface height (28" – 34" AFF)	<input type="checkbox"/>	<input type="checkbox"/>
	Counters/Bars >34" AFF (portion of main counter min. 60" long complying with Seating and Tables required)	<input type="checkbox"/>	<input type="checkbox"/>
DINING AREAS	New construction (<u>all</u> areas shall be accessible)	<input type="checkbox"/>	<input type="checkbox"/>
	Alterations/Existing (same services and décor shall be provided to all)	<input type="checkbox"/>	<input type="checkbox"/>
FOOD SERVICE LINES	Food service lines (36" min. aisle width, 42" preferred)		
Tray slide	Tray Slide (max. 34" AFF)		
	Self service shelves (min. 50% of each type in accessible reach ranges)	<input type="checkbox"/>	<input type="checkbox"/>
	Tableware and condiments (located within accessible reach ranges)	<input type="checkbox"/>	<input type="checkbox"/>
	Vending machines (controls and coin slots located within accessible reach ranges)	<input type="checkbox"/>	<input type="checkbox"/>
REACH RANGE	Reach range (15 – 48" forward reach; 9 – 54" side reach, max. 10" deep)	<input type="checkbox"/>	<input type="checkbox"/>

ELEMENT	COMPLIES (or NA)	DOES NOT COMPLY
Reach range		
Reach range	<p data-bbox="350 422 1192 548">Reach range over obstruction (< 20" deep obstruction w/ knee space, 48" AFF max. forward; 20-25" deep obstruction w/ knee space, 44" AFF max. forward reach; < 10" deep obstruction, 34" high obstruction, 54" max. side; 10-24" deep, 34" high obstruction, 46" AFF max. side reach)</p>	
INTERIOR ACCESSIBLE ROUTE	Complete INTERIOR ACCESSIBLE ROUTE section	