








ELEMENT		COMPLIES (or NA)	DOES NOT COMPLY
<b>SIGNAGE</b>			
APPLICABLE	Permanent rooms & spaces shall comply with: <ul style="list-style-type: none"> <li>▪ Raised &amp; Braille characters and Pictograms</li> <li>▪ Finish &amp; contrast</li> <li>▪ Mounting height &amp; location</li> </ul>		
	Direction to or information about shall comply with: <ul style="list-style-type: none"> <li>▪ Character proportion</li> <li>▪ Character height</li> <li>▪ Finish &amp; contrast</li> </ul>		
	International symbol of accessibility required at: <ul style="list-style-type: none"> <li>▪ Accessible parking spaces</li> <li>▪ Accessible passenger loading zones</li> <li>▪ Accessible entrances when all are not accessible</li> <li>▪ Accessible toilet and bathing facilities when all are not accessible</li> </ul>		
REQUIREMENT	Width-to-height ratio (between 3:5 and 1:1); Stroke-to-height ratio (between 1:5 and 1:10)	<input type="checkbox"/>	<input type="checkbox"/>
	Sized according to viewing distance (min. 3" high character)	<input type="checkbox"/>	<input type="checkbox"/>
	Letters and numbers (raised 1/32", upper case, sans or simple serif type w/ grade 2 Braille)	<input type="checkbox"/>	<input type="checkbox"/>
Character ht.	Raised character height (5/8" – 2" high)	<input type="checkbox"/>	<input type="checkbox"/>
			
	Pictogram (equivalent verbal description below)	<input type="checkbox"/>	<input type="checkbox"/>
Pictogram	Pictogram border (min. 6" height)	<input type="checkbox"/>	<input type="checkbox"/>
			
	Non-glare surface, characters & symbols shall contrast with their background	<input type="checkbox"/>	<input type="checkbox"/>
	Permanent rooms & spaces (wall adjacent to latch side of door, or nearest adjacent wall)	<input type="checkbox"/>	<input type="checkbox"/>
	Height (60" AFF to sign centerline) Note: New ADAAG mounting height diagrams illustrated below.	<input type="checkbox"/>	<input type="checkbox"/>
Mounting ht. & location	Location (no objects located below sign and out of door swing area)	<input type="checkbox"/>	<input type="checkbox"/>
			
	Facilities & elements required to be identified as accessible (International Symbol of Accessibility provided)	<input type="checkbox"/>	<input type="checkbox"/>
ISA	 INTERNATIONAL SYMBOL OF ACCESSIBILITY		

ELEMENT		COMPLIES (or NA)	DOES NOT COMPLY
Volume Control	Volume control telephones (phone symbol w/ waves)	<input type="checkbox"/>	<input type="checkbox"/>
	 VOLUME CONTROL PHONE SYMBOL WITH WAVES		
TDD	Text telephones (TDD symbol)	<input type="checkbox"/>	<input type="checkbox"/>
	 INTERNATIONAL TDD SYMBOL		
Hearing loss	Permanent installed assistive listening systems (sign noting availability of system + hearing loss symbol)	<input type="checkbox"/>	<input type="checkbox"/>
	 INTERNATIONAL SYMBOL FOR HEARING LOSS		