

ELEMENT		COMPLIES (or NA)	DOES NOT COMPLY
SINKS			
LAVATORIES AND SINKS	Clear floor area (min. 30" by 48" for a forward approach)	<input type="checkbox"/>	<input type="checkbox"/>
	Toe and knee clearance provided (see figs. below)	<input type="checkbox"/>	<input type="checkbox"/>
Toe and Knee Clearance			
Lavatory height	Height (max. 34" AFF)		
	Faucets (automatic; or operable with one hand, no grasping or twisting of wrist to operate)	<input type="checkbox"/>	<input type="checkbox"/>
	Exposed Pipes and Surfaces (insulated or configured to avoid contact)	<input type="checkbox"/>	<input type="checkbox"/>